

WORKS SUMMARY (cont'd)

Service Type	Area	Task	Description of Work	Work Priority	Additional Comment	Cost	Year 1	Year 2	Year 3-5
Electrical	Plant Room (battery area)	Fluorescent	Replace with suitable GRP Vapourproof fluorescent fitting	1		100	100		
Electrical	Fire Escape	Bulkhead (tungsten)	Replace with suitable fluorescent fitting	1		200	200		
Electrical	Switch Room	Fluorescent	Replace with suitable GRP Vapourproof fluorescent fitting	1		1,000	1,000		
Electrical	Air Circulation Room	Fluorescent	Replace with suitable GRP Vapourproof fluorescent fitting	1		600	600		
Electrical	Service Duct	Fluorescent	Replace with suitable GRP Vapourproof fluorescent fitting	1		400	400		
Electrical	Lift Motor room	Fluorescent	Replace with suitable GRP Vapourproof fluorescent fitting	1		400	400		
Electrical	Boiler Room Level 4	Fluorescent	Replace with suitable GRP Vapourproof fluorescent fitting	1		800	800		
Electrical	Tank Room Level 6	Fluorescent	Replace with suitable GRP Vapourproof fluorescent fitting	1		1,000	1,000		
Electrical	Plant Room	unspecified	Paint/Replace rusting isolators	1		400	400		
Electrical	Electrical Intake Room	Emergency Lighting	Circuit chart	1		200	200		
Electrical	Area Around Pool	Emergency Call System	Replace ageing buttons	1		200	200		
Electrical	Area Around Pool	Emergency Call System	Replace ageing buttons	1		400	400		