

Asset Ref	M or E	Level	Location	Equipment / Plant Ref:	Type	Qty	Manufacturer	Condition Grading	Priority Grading	Economic Life (Yrs)	Predicted Future Life (Yrs)	Comments
2.E.14	Fire	02 - Second Floor	Changing Room Plant Room 52	Smoke detector x 1				Grade A	Priority 4	20	10-15	
2.E.3	Fire	02 - Second Floor	Room 53	Manual call point x 1				Grade A	Priority 4	20	10-15	
2.E.4	Fire	02 - Second Floor	Room 53	Sounder beacon x 1				Grade A	Priority 4	20	10-15	
2.E.5	Fire	02 - Second Floor	Room 53	Smoke detectors x 2				Grade A	Priority 4	20	10-15	
3.E.18	Fire	03 - Third Floor	Room 54	Manual call point x 1				Grade A	Priority 4	20	10-15	
3.E.22	Fire	03 - Third Floor	Room 54	Smoke detector AFD x 1				Grade A	Priority 4	20	10-15	
3.E.3	Fire	03 - Third Floor	Lift Motor Room - Room 55	Manual call point x 1				Grade A	Priority 4	20	10-15	
3.E.6	Fire	03 - Third Floor	Lift Motor Room - Room 55	Smoke detector AFD x 1				Grade A	Priority 4	20	10-15	
4.E.4	Fire	04 - Fourth Floor	Boiler room - 56	Manual call point x 1				Grade A	Priority 4	20	10-15	
4.E.9	Fire	04 - Fourth Floor	Boiler room - 56	Heat / smoke detectors AFD x 5				Grade A	Priority 4	20	10-15	